

POOR LEGIBILITY

**ONE OR MORE PAGES IN THIS DOCUMENT ARE DIFFICULT TO READ
DUE TO THE QUALITY OF THE ORIGINAL**

CITY OF MOUNTAIN VIEW

SFUND RECORDS CTR
2807-91846

SFUND RECORDS CTR
88172018

April 10, 1967

FILD, Fairchild Plating Facility

George L. Norhester, Water Division Engineer

INDUSTRIAL WASTE TREATMENT

A meeting convened by Al Glisson of Stoyan, Stoyan, etc., James A. Building Department, Fire Service, Roger Higgin & Associates, Public Works, representatives from Fairchild Plating Inc. to be Bergstrom, and the building contractor, was held at 9:00 A.M. in the Public Works Conference Room for the purpose of discussing the proposed Industrial waste treatment facilities.

It was concluded that the system as proposed on the May 1st Corporation drainage received March 27 is adequate if there is a recording of the pH of wastes as discharged from the plating department.

It was agreed that Fairchild will furnish results of off-take analyses for public consumption by the City after the facility is in operation.

There are to be drop inlets or chambers constructed on the storm drain system at the confluence of streams.

Reported assurance was given by Fairchild that the building plumbing is so arranged that everything except waste from the sanitary facilities must go through the centralizing tanks.

At conclusion it was pointed out that the discharger is expected to comply with the provisions of Ordinance 175.630 and that the City by approving facilities assumes no responsibility for operation.

GEORGE L. NORHESTER

ml

City Manager
Dir. Public Works
Bldg.
Engineering Operations
Dept. Public Works
Water Division Engineer
V